

GENERAL:

- Specify that veneer plaster products are from a single Manufacturer for each veneer plaster system indicated.
- Use of lath is preferable. Specify galvanized steel lath in conjunction with acoustic plaster to eliminate rust. Where highest corrosion resistance is considered desirable specify that lathing accessories such as corner and casing beads be made of zinc alloy, otherwise call for galvanized steel.
- Provide ample control joints in stucco, particularly in overhang.
- Specify a Veneer Plaster Product from one of the following:
 - a. Gold Bond Building Products Div., National Gypsum Co.
 - b. United States Gypsum Co.
 - c. Georgia Pacific Corp.
- **Do not use EFIS Systems in areas accessible to students.**
- Specify that substrates are examined prior to installation which veneer plaster construction attaches to or abuts.
- Specify ample number of control joints.

END OF SECTION 09215