

**GENERAL:**

All color selections shall be made from district approved color palette including field color and one accent color. All surfaces that are to receive floor covering shall be tested for moisture content prior to installation. The owner and flooring contractor shall be provided written documentation of moisture content prior to installation. The flooring contractor shall accept this moisture level as non-detrimental to the product and installation components and guarantee accordingly.

**Locations for Acceptable Products**

Classrooms – VET only  
Corridors – VCT, VET or Porcelain Tile  
Media Centers – Carpet, (Porcelain Tile, VCT or VET permitted at entrance only)  
Cafeteria – VCT or VET  
Multipurpose – Carpet, VCT or VET  
Administrative – Carpet (Porcelain Tile in Heavy Traffic/Public Reception Areas)

**NOTE:** For More on Carpet, see Section 09680. For more on Porcelain Tile, see Section 09311.

**Tile Flooring**

**Acceptable Products**

- Rubber Tile: FS SS-T-312, Type II; 12" x 12" x 1/8" gauge (used for special use situations only per project)
- Raised Profile Rubber Tile (used for special use situations only per project)
- Vinyl Enhanced Tile (VET): ASTM F 1066, 12" x 12" x 1/8" gauge
  - AZROCK CortinaStone (or DCPS approved Equivalent)
- Vinyl Composition Tile (VCT): FS SS-T-312, Type IV; 12" x 12", 1/8" gauge.  
VCT Compression Detail and/or Acceptable Products (**Minimum PSI 125**)
  - Armstrong Bio-Based Tile (or DCPS approved Equivalent)
  - Armstrong Excelon (or DCPS approved Equivalent)
  - Manington Products (or DCPS approved Equivalent)

**Mastic Adhesive**

**All mastic adhesive shall be rated for moisture at a minimum of 7 lbs - 10 lbs for any floor at or below grade. All mastic adhesive shall be rated at a pH of 10-12.**

The flooring sub-contractor shall strip the VCT of its factory applied protective coating and install three (3) coats of floor finishing product containing a minimum of 25% floor solids, prior to substantial completion.

Approved Products as follows:

- Spartan On & On
- Spartan I-Shine
- Johnson Time-Saver
- OR DCPS Approved Equivalent

**Contractor to furnish to school or appropriate maintenance yard, not less than one box for each 50**

**boxes installed (fraction thereof) for each type, color, pattern and size installed.**

Vinyl Wall Base: Comply with FS SS-W-40, Type II, with matching end stops. No preformed or molded corner units are required. **Score backside of base at outside & inside corners.**

Height: 4" thickness

Thickness: 1/8" gauge

Style: standard top-set cove finish: matte Comply with FS RR-T-650, Type A, sanded backs with stair tread adhesive.

**NOTE: On Retrofits, do not place vinyl wall base over existing wood, ceramic or porcelain wall base.**

Resilient Stair Tread:

Provide concrete stair with abrasive surface at nosings.

**END OF SECTION 09660**