

**In general the district expects universal, heavy duty, tamper resistant toilet accessories.**

**Toilet Tissue Dispensers**

For all projects in all toilet rooms, toilet paper dispenser to be for the standard size toilet paper roll but use a heavy duty steel bar dispenser which holds two (2) rolls of Paper. The Toilet Paper dispenser shall be **Bobrick B-2746** or DCPS approved equivalent. **Toilet paper dispensers shall be through bolted in the High Density Polyethylene partition utilizing tamper proof hardware. Do not use manufactures provided hardware.**

**Paper Towel Dispensers – Only in single occupant toilets**

Recommended that we use Jumbo paper towel dispensers (**Boberick B-2860** stainless steel surface mounted) installed on  $\frac{3}{4}$ " **High Density Polyethylene** Board (PRB). The PRB shall extend a minimum of 6" beyond each side of the accessory for mounting purposes. The PRB shall be installed as follows: CMU - expansion bolted and glued to the CMU (not ceramic tile); Gypsum board products - the PRB shall be securely fastened to the gypsum wall board by screws to wood backing behind gypsum wall board.

Note: When project is a retrofit and no backing is present, it is acceptable to fasten to wall via a glue and toggle-bolt combination through ceramic tile and drywall.

Note: **Do not use Manufactures Provided Hardware**

**Electric Hand Dryers ONLY – Group Toilets**

Prefer recessed/semi-recessed vandal-resistant design, semi recess mounted, cast iron finish, touch-less operation) Minimum of two per group toilets restroom facilities.

**Refer to Electric Hand Dryers used in DCPS group toilet prototype design (Sandalwood - Ft. Caroline Model)**

**Soap Dispensers**

Bobrick Model B-2111 or DCPS approved equivalent, installed on  $\frac{3}{4}$ " **High Density Polyethylene** Board (PRB). The PRB shall extend a minimum of 6" beyond each side of the accessory for mounting purposes. The PRB shall be installed as follows: CMU - expansion bolted and glued to the CMU (not ceramic tile); Gypsum board products - the PRB shall be securely fastened to the gypsum wall board by screws to wood backing behind gypsum wall board.

Note: When project is a retrofit and no backing is present, it is acceptable to fasten to wall via a glue and toggle-bolt combination through ceramic tile and drywall.

Note: **Do not use Manufactures Provided Hardware**

**Toilet Flush Valves**

Toilets Flush Valves (touch-less operation, electrically wired) only within all group toilet restrooms facilities

**Sink Faucets**

Sink Faucets (touch-less in operation, electrically wired, heavy duty, non swiveling) only within all Group toilets restrooms facilities

**Other Requirements**

- Stainless Steel Mirrors within all Group toilets restrooms facilities minimum of two per group toilets restrooms.
- Provide feminine napkin disposal at each female water closet in Administrative and Facility Restrooms only.
- Provide stainless steel framed mirror without shelf, minimum width x length as required by the ADA. Mirror for handicapped usage shall have the bottom mounted at minimum height required by ADA above the floor or shall be a fixed tilt unit. Provide above each lavatory in administrative and faculty toilet rooms.
- See Plumbing Section 15500 for vanity and floor drain guidelines

**END OF SECTION 10800**